

XRSUPER6 PROGRAMMING SHEET

Name _____ Account Number _____ Date _____

Address _____ City _____ State _____ Zip _____

COMMUNICATION

Communication Type: **NONE** DD 4-2 M2E CID NET
 Retry Time -- -- (3 to 15 sec.)
 Check-in Time -- -- (0 to 240 min.)
 Fail Time -- -- (0 to 240 min.)
 Network Trouble **NO** YES
 Account Number -- -- -- (1 to 65,535)
 Transmission Delay -- -- (0, 15 to 45 sec., Default =30)
 DTMF **NO** **YES**
 Defer Test **NO** **YES**
 Events Manager **SND** DLY KEEP
 Test Frequency -- -- (0 to 60 days)
 Test Time -- : -- AM PM

Receiver 1

Alarm **NO** **YES**
 Supv/Trouble **NO** **YES**
 O/C & User **NO** **YES**
 Test Report **NO** **YES**
 Backup **NO** YES
 First Phone #: -----

 Second Phone #: -----

Receiver 2

PagerDirect™ **NONE** NUM
 Alarm **NO** YES
 Supv/Trouble **NO** YES
 O/C & User **NO** YES
 Test Report **NO** YES
 Backup **NO** YES
 First Phone #: -----

 Second Phone #: -----

 Pager ID #: -----

REMOTE OPTIONS

Remote Key -----
 Manufacturer Authorization **NO** YES
 Armed Rings -- -- (0 to 15)
 Disarmed Rings -- -- (0 to 15)
 Alarm Receiver **NO** YES
 Service Receiver **NO** **YES**
 Disarm **NO** YES

SYSTEM REPORTS

Opening/Closing Reports **NO** YES LTD ALM
 Abort Reports **NO** YES
 Zone Restoral Reports **NO** **YES** DISARM
 Bypass Reports **NO** **YES**
 Code Change Reports **NO** YES
 Ambush **NO** YES

SYSTEM OPTIONS

Mode **A/P** H/A
 Closing Code **NO** YES
 Entry Delay 1 -- -- (30 to 250 sec., Default = 30)
 Entry Delay 2 -- -- (30 to 250 sec., Default = 60)
 Exit Delay -- -- (45 to 250 sec., Default = 60)
 Cross Zone Time -- -- (4 to 250 sec.)
 Power Fail Delay -- (0 to 9 hrs.)
 Reset Swinger Bypass **NO** YES
 Telephone Access **NO** YES
 Zone Activity Hours -- (0 to 9 hrs.)
 Arm Activity Days -- (00 to 99 days)
 Time Change **NO** **YES**
 Hours from GMT -- -- (0 to 23 hrs.)
 Time Display **NO** **YES**
 House Code -- -- (0 to 50)
 Detect Wireless Jamming **NO** YES
 Wireless Audibles **ANY** **DAY** MIN
 Enable Keypad Panic Keys **NO** **YES**
 SIA CP-01 **NO** **YES**

BELL OPTIONS

Bell Cutoff Time -- -- (0 to 15 min.)
 Automatic Bell Test **NO** YES
 Bell Output -- -- (0 to 4, 31-34, 41-44)

Bell Action . . .

Fire Zones	Steady	Pulse	Temporal	None
Burglary Zones	Steady	Pulse	Temporal	None
Supervisory Zones	Steady	Pulse	Temporal	None
Panic Zones	Steady	Pulse	Temporal	None
Emergency Zones	Steady	Pulse	Temporal	None
Auxiliary 1 Zones	Steady	Pulse	Temporal	None
Auxiliary 2 Zones	Steady	Pulse	Temporal	None

OUTPUT OPTIONS

Cutoff Output	1	2	3	4
Cutoff Time	--	--	(0 to 15 min.)	
Comm Fail Output	--	--	(0 to 4, 31-34, 41-44)	
Fire Alarm Output	--	--	(0 to 4, 31-34, 41-44)	
Fire Trouble Output	--	--	(0 to 4, 31-34, 41-44)	
Ambush Output	--	--	(0 to 4, 31-34, 41-44)	
Entry Output	--	--	(0 to 4, 31-34, 41-44)	
Exit Output	--	--	(0 to 4, 31-34, 41-44)	
Ready Output	--	--	(0 to 4, 31-34, 41-44)	
Armed Output	--	--	(0 to 4, 31-34, 41-44)	
Burglary Output	--	--	(0 to 4, 31-34, 41-44)	
Ground Start Output	--	--	(0 to 4)	
Cell Backup Output	--	--	(0 to 4)	
Arm-Alarm Output	--	--	(0 to 4, 31-34, 41-44)	

Note: Factory default values are shown in **bold** type.

OUTPUT INFORMATION

Output No.	Output Name	Serial Number	Supervision Time (0, 3, 60, 240) Default = 240
31			
32			
33			
34			
41			
42			
43			
44			

Note: Assign Output Numbers 31 to 34 for slow response time wireless outputs (activates within 15 seconds) or 41 to 44 for fast response time wireless outputs (activates within 1 second).

ZONE INFORMATION

XRSuper6 Zone Information	Key Fob	Type	Area	Wireless	1101 Contact	DMP Wireless			Disarmed Open			Disarmed Short			Armed Open			Armed Short			Entry Delay	Cross Zone	Priority	TGL Style			
						1101 External Contact N/O?	1114 Contact	Supervision Time	1142 LED Operation	Message	Output *	Action	Message	Output *	Action	Message	Output *	Action	Message	Output *					Action		
Zone Type Defaults Assign Area and Disarmed condition for NT, DY, EX, A1, and A2 only. Assign Prewarn and Entry Delay for EX only. Assign Style for AR only. Assign 31 to 34 or 41 to 44 to Key Fobs or wireless output modules.	N or Y	NT DY EX FI PN EMSV A1 A2 FV AR	INT BDRM PERIM	N or Y	INT or EXT	1 2 3 4	0 3 60 240	N or Y	-	-	-	-	-	-	-	-	-	-	-	-	1 or 2	N or Y	N or Y	TGL ARM DIS STEP MNT			
	NIGHT	N	NT		N	INT	1	240	Y	-	0	S	-	0	S	-	0	S	-	0	S	Y	N	N			
	DAY	N	DY		N	INT	1	240	Y	T	0	S	T	0	S	A	0	S	A	0	S	Y	N	N			
	EXIT	N	EX		N	INT	1	240	Y	-	0	S	-	0	S	-	0	S	-	0	S	Y	1-2	N	N		
	FIRE	N	FI		N	INT	1	240	Y																		
	PANIC	N	PN		N	INT	1	240	Y																		
	EMERGENCY	N	EM		N	INT	1	240	Y																		
	SUPERVISORY	N	SV		N	INT	1	240	Y																		
	AUXILIARY 1	N	A1		N	INT	1	240	Y	T	0	S	A	0	S	A	0	S	A	0	S						
	AUXILIARY 2	N	A2		N	INT	1	240	Y	T	0	S	A	0	S	A	0	S	A	0	S						
	FIRE VERIFY	N	FV		N	INT	1	240	Y																		
	ARMING	N	AR		N	INT	1	240	Y																		
	Zone Name	Serial Number	* Outputs = 1 to 4, 31 to 34, or 41 to 44. █ = This function not available for this zone type.																								
	1																										
	2																										
3																											
4																											
5																											
6																											
7																											
8																											
9																											
10																											
21																											
22																											
23																											
24																											

